# GETRIEBEBAU NORD Member of the NORD DRIVESYSTEMS Group



SK CU4-24V-123-B-C

Mains unit

Part number: 275 271 608

## **NOTICE**

# Validity of this document

This document is only valid in combination with the operating instructions for the relevant electronic drive technology and under strict compliance with the safety and warning instructions which they contain. Safe commissioning of this module and the electronic drive technology depends on the availability of this information.

## Scope of delivery

1 x	Module	SK CU4-24V-123-B-C	
1 x	Mains voltage cable set	brown / black* * incl. fuse (5A slow-acting)	
1 x	24 VDC cable set	brown / blue	
1 x	Connection cable (analogue signal)	black	
1 x	Burden resistor	500 Ω	
2 x	Connecting screws	M4 x 20, cross-head	



## Field of use

Mains unit for use in a decentralised electronic drive technology frequency inverter. The voltage / frequency converter which is integrated into the module enables conversion of analogue signals from a potentiometer into a digital pulsed signal. This pulsed signal can be interpreted as an analogue signal by certain digital inputs of the drive electronics.

The module has a water-repellent coating. Reliable operation is retained even with condensation.

### Technical data

Temperature range	-25°C 50 °C
Temperature class	Class 3K3

Vibration resistance	3M7
Protection class	IP20

Designation	Terminal	Data
Module power supply	L1 + L2	100 V AC 240 V AC
Output voltage (load capacity)	x 1) + 40	24 VDC ± 10 % (≤ 420 mA)
Analogue input - reference voltage	11	10 VDC ±0.2 V, ≤ 5 mA (output)
Analogue input	12 + 14	Resolution: 8 Bit, precision: 0.2 V 2)
Frequency output	B1	PLC-compatible as per EN 61131-2
		Low: 0 V, High: 24 V
		Clock frequency: approx. 1 – 32 kHz

- Depending on the frequency inverter version: SK TU4: x = Terminal 43, SK CU4: x = Terminal 44
- 2) For connecting a potentiometer (5 10 kΩ). A 500 Ω burden resistor (enclosed) must be used for the evaluation of 0/4 20 mA signals


Technical Information / Datasheet	SK CU4-24V-123-B-C			
Power supply	TI 275271608	V 1.0	5115	EN



## Installation

Installation location	In defined option slot inside the frequency inverter (SK 1xxE, 2xxE)
Fastening	with screw fastenings

# Installation steps (example illustration)



<sup>\*)</sup> Before carrying out installation step 1 it may be necessary to remove the control terminal bar ( A ), The control terminal bar ( A ) must be fitted after installation step 2.

2 / 4 TI 275271608 - 5115



## **Connections**

Terminals Screw terminals		1 terminal bar with 16 connections, (5 mm spacing)
Cable cross section	0.142.5 mm	AWG 14-26
PE connection	Via device	Via screws for installation in the device

#### **Control terminal details**

## Labelling, Function

AIN: Analogue input FOUT: Digital output (DO): Pulse output 10 V: Reference voltage for AIN ON L/R: Digital output (DO): Enable L/R 24 V: Control voltage (output) L: Mains connection for a phase

GND: Reference potential for digital signals PE: Earth

AGND: Reference potential for analogue

signals

## **Connections, Functions**

## SK CU4-24V-...


Labelling	Function	
PE	PE	<u>e</u>
PE	PE	al e
		tenti
L2	2nd Phase	od sı
		~ Mains potential level
L1	1st Phase	₹
40	GND	
B1	FOUT	_
12	AGND	leve
14	<b>14</b> AIN1	
11	10 V	pote
40	GND	DC
44	24 V	24 V DC potential level
40	GND	``
44	24 V	



Compliance with the radio interference class can only be ensured if the mains filter is active (jumper plugged into the upper position).

In the event of use in non-earthed networks (IT network), the mains filter must be deactivated.

To do this, the jumper must be transferred from the top to the bottom.



TI 275271608 - 5115



Meaning, Functions		Description / Technical data			
Terminal			Parameter		
No.	Designation	Meaning	No.	Function of factory setting	
Analogue inputs		Only in combination with SK TU4-24V         Connection of an analogue signal         (5-10 kΩ potentiometer, external control unit or similar)         Resolution 8Bit       + 10 V Reference voltage: 5 mA not short-circuit resistant			
		Accuracy 0.2 V V= 010 V I= $0/4$ 20 mA Burden resistor (500 $\Omega$ ) enclosed	ē	11 12 R=10k	
11	10V REF	+ 10 V Reference voltage	-	-	
12	AGND	Analogue reference potential GND	-	-	
14	AIN1+	Analogue input 1	-	-	
Cont	rol voltage	For the supply of frequency inverters and accessories with a 24 V control voltage			
		24 V DC ± 10 % 420 mA (total) Short circuit and limited excess temperature or overload monitoring available.	Can also be used as an input (in this case, do not connect L1 and L2) if the module is only to be used as a voltage/frequency converter (for connecting a potentiometer).		
44	24V	Voltage output	-	-	
40	GND / 0V	Reference potential GND	-	-	
Digit	al outputs	Digital signals for controlling an electronic drive device			
·		PLC-compatible as per EN61131-2 Low: 0 V, High: 24 V Clock frequency: ~1 – 32 kHz	Pulses for evaluation of the digital input functions of an SK 2xxE frequency inverter, size 1 - 3 P420 [-02]/[-03] = 26/27,  Analogue meaning P400 [-06]/[-07].		
B1	1 FOUT Frequency output P400/P420 -		-		
40	GND	Reference potential GND	-	-	
Mains connection		Mains voltage connection			
		Mains connection, 100 - 240 V or 380 - 500 V, depending on the module			
L1	L1	Mains supply 1 Phase	-	-	
L2	L2/N	Mains supply 2 Phase / N	-	-	
PE	PE	PE, Earth	-	-	

# Further documentation (<u>www.nord.com</u>)

Document Name	
BU 0135	Motor starter manual SK 135E, SK 175E
BU 0180 Frequency inverter manual SK 180E, SK 19	

ı	Document	Name	
ı	<u>BU 0200</u>	Frequency inverter manual SK 2xxE	

4 / 4 TI 275271608 - 5115